



CERTIFICATE OF ANALYSIS

Client: TTI Environmental Inc.
 1253 North Church St.
 Moorestown NJ 08057

Report Date: 7/10/2017
Report No.: 539374 - Lead Water
Project: Harrison BOE High School
Project No.: 17-286

Client: TTI379

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6269587 **Location:**Kitchen - Sink Faucet **Result(ppb):**<2.00
Client No.:HS-SF-K

Lab No.:6269588 **Location:**Kitchen - Sink Faucet **Result(ppb):**<2.00
Client No.:HS-SF-K

Lab No.:6269589 **Location:**Kitchen - Sink Faucet **Result(ppb):**<2.00
Client No.:HS-SF-K

Lab No.:6269590 **Location:**Kitchen - Ice Machine **Result(ppb):**<2.00
Client No.:HS-IM-K

Lab No.:6269591 **Location:**1st FL Corridor D149 Boys Side - Water Cooler **Result(ppb):**<2.00
Client No.:HS-WC-D149

Lab No.:6269592 **Location:**1st FL Corridor D142 Girls Side - Water Cooler **Result(ppb):**<2.00
Client No.:HS-WC-D142

Lab No.:6269593 **Location:**1st FL Corridor B114 Boys Side - Water Cooler **Result(ppb):**<2.00
Client No.:HS-WC-B114

Lab No.:6269594 **Location:**1st FL Corridor B112 Girls Side - Water Cooler **Result(ppb):**<2.00
Client No.:HS-WC-B112

Lab No.:6269595 **Location:**1st FL A106 Girls Locker - Water Cooler **Result(ppb):**<2.00
Client No.:HS-WC-A106

Lab No.:6269596 **Location:**1st FL A106 Girls Locker - Water Cooler **Result(ppb):**<2.00
Client No.:HS-WC-A106

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 6/20/2017
Date Analyzed: 07/07/2017
Signature:
Analyst: Chad Shaffer

Approved By:
 Frank E. Ehrenfeld, III
 Laboratory Director

CERTIFICATE OF ANALYSIS

Client: TTI Environmental Inc.
1253 North Church St.
Moorestown NJ 08057

Report Date: 7/10/2017
Report No.: 539374 - Lead Water
Project: Harrison BOE High School
Project No.: 17-286

Client: TTI379

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6269597 **Location:**1st FL A110 Boys Locker - Water Cooler **Result(ppb):**<2.00
Client No.:HS-WC-A110

Lab No.:6269598 **Location:**1st FL A110 Boys Locker - Water Cooler **Result(ppb):**<2.00
Client No.:HS-WC-A110

Lab No.:6269599 **Location:**1st FL Corridor Across A124 - Water Cooler **Result(ppb):**<2.00
Client No.:HS-WC-CA124

Lab No.:6269600 **Location:**1st FL Corridor Across A124 - Water Cooler **Result(ppb):**<2.00
Client No.:HS-WC-CA124

Lab No.:6269601 **Location:**Room A124 - Sink Faucet **Result(ppb):**<2.00
Client No.:HS-SF-A124

Lab No.:6269602 **Location:**Room A124 - Ice Machine **Result(ppb):**<2.00
Client No.:HS-IM-A124


Lab No.:6269603 **Location:**Auxiliary Gym A126 Outside - Outside Bubbler Fountain **Result(ppb):**<2.00
Client No.:HS-BF-AGO


Lab No.:6269604 **Location:**Culinary Classroom D141 - Sink Faucet **Result(ppb):**<2.00
Client No.:HS-SF-CCD141

Lab No.:6269605 **Location:**Culinary Classroom D141 - Sink Faucet **Result(ppb):**<2.00
Client No.:HS-SF-CCD141

Lab No.:6269606 **Location:**Culinary Classroom D141 - Sink Faucet **Result(ppb):**<2.00
Client No.:HS-SF-CCD141

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 6/20/2017
Date Analyzed: 07/07/2017
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: TTI Environmental Inc.
1253 North Church St.
Moorestown NJ 08057

Report Date: 7/10/2017
Report No.: 539374 - Lead Water
Project: Harrison BOE High School
Project No.: 17-286

Client: TTI379

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6269607 **Location:**1st FL Men Main Office - Sink Facuet **Result(ppb):**<2.00
Client No.:HS-SF-MMO

Lab No.:6269608 **Location:**1st FL Women Main Office - Sink Facuet **Result(ppb):**<2.00
Client No.:HS-SF-WMO

Lab No.:6269609 **Location:**2nd FL Girls Bathroom D216 - Water Cooler **Result(ppb):**<2.00
Client No.:HS-WC-D216


Lab No.:6269610 **Location:**2nd FL Girls Bathroom D216 - Water Cooler **Result(ppb):**<2.00
Client No.:HS-WC-D216


Lab No.:6269611 **Location:**2nd Fl Boys Bathroom D213 - Water Cooler **Result(ppb):**<2.00
Client No.:HS-WC-D213

Lab No.:6269612 **Location:**2nd Fl Boys Bathroom D213 - Water Cooler **Result(ppb):**<2.00
Client No.:HS-WC-D213

Lab No.:6269613 **Location:**2nd FL Teachers Lounge D204 - Sink Faucet **Result(ppb):**<2.00
Client No.:HS-WC-D204

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 6/20/2017
Date Analyzed: 07/07/2017
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: TTI Environmental Inc.
1253 North Church St.
Moorestown NJ 08057

Report Date: 7/10/2017
Report No.: 539374 - Lead Water
Project: Harrison BOE High School
Project No.: 17-286

Client: TTI379

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6269614 **Location:**3rd FL Girls Bathroom D313 - Water Cooler **Result(ppb):**<2.00
Client No.:HS-WC-D313

Lab No.:6269615 **Location:**3rd FL Girls Bathroom D313 - Water Cooler **Result(ppb):**<2.00
Client No.:HS-WC-D313

Lab No.:6269616 **Location:**3rd FL Girls Bathroom D315 - Water Cooler **Result(ppb):**<2.00
Client No.:HS-WC-D315


Lab No.:6269617 **Location:**3rd FL Girls Bathroom D315 - Water Cooler **Result(ppb):**<2.00
Client No.:HS-WC-D315


Lab No.:6269618 **Location:**1st FL Pool Boys Locker A141 - Water Cooler **Result(ppb):**<2.00
Client No.:HS-WC-A141

Lab No.:6269619 **Location:**1st FL Pool Boys Locker A141 - Water Cooler **Result(ppb):**<2.00
Client No.:HS-WC-A141

Lab No.:6269620 **Location:**Field House Snack Shop **Result(ppb):**56.5
Client No.:HS-SF-FHSS

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 6/20/2017
Date Analyzed: 07/10/2017
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: TTI Environmental Inc.
1253 North Church St.
Moorestown NJ 08057

Report Date: 7/10/2017
Report No.: 539374 - Lead Water
Project: Harrison BOE High School
Project No.: 17-286

Client: TTI379

Appendix to Analytical Report:

Customer Contact: TTI Reports

Analysis: AAS-GF - ASTM D3559-08D, USEPA 40CFR 141.11B, 2010

This appendix seeks to promote greater understanding of any observations, exceptions, special instructions, or circumstances that the laboratory needs to communicate to the client concerning the above samples. The information below is used to help promote your ability to make the most informed decisions for you and your customers. Please note the following points of contact for any questions you may have.

iATL Customer Service: customerservice@iatl.com

iATL Office Manager: cdavis@iatl.com

iATL Account Representative: Shirley Clark

Sample Login Notes: See Batch Sheet Attached

Sample Matrix: Water

Exceptions Noted: See Following Pages

General Terms, Warrants, Limits, Qualifiers:

General information about iATL capabilities and client/laboratory relationships and responsibilities are spelled out in iATL policies that are listed at www.iATL.com and in our Quality Assurance Manual per ISO 17025 standard requirements. The information therein is a representation of iATL definitions and policies for turnaround times, sample submittal, collection media, blank definitions, quantification issues and limit of detection, analytical methods and procedures, sub-contracting policies, results reporting options, fees, terms, and discounts, confidentiality, sample archival and disposal, and data interpretation.

iATL warrants the test results to be of a precision normal for the type and methodology employed for each sample submitted. iATL disclaims any other warrants, expressed or implied, including warranty of fitness for a particular purpose and warranty of merchantability. iATL accepts no legal responsibility for the purpose for which the client uses test results. Any analytical work performed must be governed by our Standard Terms and Conditions. Prices, methods and detection limits may be changed without notification. Please contact your Customer Service Representative for the most current information.

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA LAP LLC, or any agency of local, state or province governments nor of any agency of the U.S. government.

This report shall not be reproduced except in full, without written approval of the laboratory.

Information Pertinent to this Report:

Analysis by AAS Graphite Furnace:

- ASTM D3559-08D, USEPA 40CFR 141.11B, 2010
- USEPA 200.9Pb, AAS-GF, RL <2 ppb/sample
- USEPA SW 846-7000B:7421 - Pb(AAS-GF, RL <2 ppb/sample)

Certification:

- NYS-DOH No. 11021
- NJDEP No. 03863

Regulatory limit for lead in drinking water is 15.0 parts per billion as cited in EPA 40 CFR 141.11 National Primary Drinking Water Regulations, Subpart B: Maximum contaminant levels for inorganic chemicals.

All results are based on the samples as received at the lab. iATL assumes that appropriate sampling methods have been used and that the data upon which these results are based have been accurately supplied by the client.

Sample results are not corrected for contamination by field or analytical blanks.

PPB = Parts per billion. 1 µg/L = 1 ppb MDL = 0.24 PPB Reporting Limit (RL) = 2.0 PPB

Disclaimers / Qualifiers:

There may be some samples in this project that have a "NOTE:" associated with a sample result. We use added disclaimers or qualifiers to inform the client about something that requires further explanation. Here is a complete list with highlighted disclaimers pertinent to this project. For a full explanation of these and other disclaimers, please inquire at customerservice@iatl.com.

Water Sample Turbidity greater than 1.0 NTU does not meet Federal and NJ State Primary & Secondary Drinking Water Standards.